

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-1525:100 Page 1 of 1

CATEGORY: Misc. Device/Control Unit Accessories

LISTEE: Notifier Integrated Systems, 11917 Plantside Drive, Louisville, KY 40299 Contact: Larry Flood (203) 484-1200 Fax (203) 484-1036

DESIGN: Model UniNet 2000 and *Uni-Fire-Net proprietary and central station receiving unit. Refer to listee's data sheet for detailed product description and operational considerations. System components:

UWS-586P	Unlisted Component Computer
PCLTA-10	Communication Board
WSSUP	Watchdog Supervisory Board
SoundBlaster 16	Audio Board
3C509B-Combo Ethernet Crad	
QM33240STA	Hard Drive
C4423/CD532E CD ROM	
PRN-4	Printer
Flashpoint 128PLI	Communication Board
PLI8R	Digi-Board
N/A	Monitor (Any monitor listed for fire protective signaling)

RATING: 120 VAC, 2A

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as proprietary and central station receiving units for use with listee's separately listed compatible fire alarm control units.

*Rev. 07-06-99



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 12, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager